




**Lancashire Trade Frames Ltd
Unit 7, Meadow Business Park
Meadow Lane
Brightmet
Bolton
Lancashire BL2 6PT**

The above company's PVC-U windows have been assessed against the requirements of the British Fenestration Ratings Committee criteria for the energy rating of windows and achieved the following ratings:

| Window system | Rating band | Rating value [kWhm ⁻² (year) ⁻¹] | U _{window} (Wm ⁻² K ⁻¹) | g _{window} | L _{factor} (Wm ⁻² K ⁻¹) |
|---|-------------|--|--|---------------------|--|
| Spectus Elite 70 Outward Opening PVC-U window Optiwhite/Argon/K glass (Ulmke LPS1 stainless steel spacer) | B | -7 | 1.7 | 0.50 | 0.00 |
| Spectus Elite 70 Outward Opening PVC-U window Optifloat/Argon/K glass (Ulmke LPS1 stainless steel spacer) | C | -16 | 1.7 | 0.46 | 0.00 |



Signed on behalf of the British Board of Agrément:

Date: 5th June 2008

British Board of Agrément, Bucknalls Lane, Garston, Watford, Hertfordshire WD25 9BA
Telephone: 01923 665300
Fax: 01923 665301

©2008

e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk