




**Lancashire Trade Frames Ltd
 Unit 7, Meadow Business Park
 Meadow Lane
 Brightmet
 Bolton
 Lancashire BL2 6PT**

The above company's PVC-U windows have been assessed against the requirements of the British Fenestration Ratings Committee criteria for the energy rating of windows and achieved the following ratings:

Window system	Rating band	Rating value [kWhm ⁻² (year) ⁻¹]	U _{window} (Wm ⁻² K ⁻¹)	g _{window}	L _{factor} (Wm ⁻² K ⁻¹)
Spectus Elite 70 Outward Opening PVC-U window Optiwhite/Argon/K glass (Ulmke LPS1 stainless steel spacer)	B	-7	1.7	0.50	0.00
Spectus Elite 70 Outward Opening PVC-U window Optifloat/Argon/K glass (Ulmke LPS1 stainless steel spacer)	C	-16	1.7	0.46	0.00



Signed on behalf of the British Board of Agrément:

Date: 5th June 2008